

# Utah Department of Environmental Quality

## Division of Drinking Water

### Public Water System Inventory Report

Run Date:  
08/04/2011 12:15 pm

**PWS ID:** UTAH16015      **Name:** SOUTH FORTY RV PARK

**Legal Contact:** PETERSON, JIM      **Rating:** Approved  
JIM PETERSON      **Rating Date:** 11/22/2010

**Address:** P.O. BOX 279      **Activity Status:** Active  
MARYSVALE, UT 84750

**Phone Number:** 435-326-2056

**City Served (Area):**

**County:** PIUTE COUNTY

**System Type:** Non-community      **Last Inv Update:** 04/29/2010      **Avg Daily Prod:**

**Activity Status Cd:** Active      **Last Snty Srv Dt:** 10/12/2009      **Total Dsgn Cap:**

**Population:** 250      **Surveyor:** ROGER FOISY      **Total Emerg Cap:**

**Oper Period:** 5/1 to 9/30

**Gal/Day   Gal/Min**

### Contacts

Contact Type	Name	Title	Phone Numbers		Email Address
			Office	Emergency	
AC	PETERSON, JIM				

### Service Connections

Connection Type	Meter Type Code	Meter Size	Number Connections
Commercial	Unknown	0	76
			76 Total Svc Connections

### Storage

**Total Storage:** 7,700 GAL      **Number of Units:** 1      **Adequate Capacity:** NO

No.	Name	Type	Effective Volume	Constr Matrl	Overflow Elev	Activity Status	Press'd
ST001	STORAGE FACILITY ST001	Ground	7,700 GAL			A	NO

### Pumping Stations

Facility No	Facility Name	Activity Status	Capacity	Avail	Emerg Power	Operating Category	Total Dynamic Head
PF001	PUMP FACILITY	A		P			

### Distribution System

Pump Type	Total Dyn Head ft H2O   P.S.I.	Pressure Adequate	Cross Connection	Auhority Statement
		No		

### Sources

No.	Source Name	Activity Status	Source Type	Well Dia.	Safe Yield *	Pump Capacity	Location Data On File	Water Type	Availability	Period of Operation	Grnd Wtr Indicator
WS001	PETERSON RV PARK WELL	Active	WL		13.33 GPM	20 GPM	Yes	GW	Seasonal	5/1 to 9/30	

\*Reports measured flow for wells, approved design capacity for all other sources.